

PRATT & LAMBERT - WICHITA DIVISION -- 725-402 -- 8010-00-161-7425

=====
Product Identification
=====

Product ID:725-402

MSDS Date:01/01/1985

FSC:8010

NIIN:00-161-7425

MSDS Number: BDDPD

=== Responsible Party ===

Company Name:PRATT & LAMBERT - WICHITA DIVISION

Emergency Phone Num:316-733-1361

CAGE:PRATT

=== Contractor Identification ===

Company Name:PRATT & LAMBERT

Address:250 PETTIT AVE

Box:2153

C

City:BELLMORE

State:NY

ZIP:11710

Country:US

Phone:800-647-2253

CAGE:PRATT

Company Name:PRATT AND LAMBERT INC

Address:945 BURLINGTON

Box:206

City:KANSAS CITY

State:MO

ZIP:64141

Country:US

CAGE:92216

=====
Composition/Information on Ingredients
=====

Ingred Name:NAPHTHA (PETROLEUM SPIRITS OR BENZIN)

CAS:8030-30-6

RTECS #:SE7555000

Fraction by Wt: 35.0%

OSHA PEL:100 PPM

Ingred Name:LEAD (SARA III)

CAS:7439-92-1

RTECS #:OF7525000

Fraction by Wt: 0.11%

OSHA PEL:0.05 MG/M3;1910.10

25
ACGIH TLV:0.15 MG/M3;DUST 9192
EPA Rpt Qty:1 LB
DOT Rpt Qty:1 LB

Ingred Name:ZINC CHROMATE
Fraction by Wt: < 5%

Ingred Name:TRIETHYLAMINE (SARA III)
CAS:121-44-8
RTECS #:YE0175000
Fraction by Wt: 0.4%
OSHA PEL:25 PPM/15 STEL
ACGIH TLV:10 PPM/15 STEL; 9293
EPA Rpt Qty:5000 LBS
DOT Rpt Qty:5000 LBS

=====
===== Hazards Identification =====

Effects of Overexposure:INHALED-ANESTHETIC, IRRITATE AIRWAY; SKIN/EYE
IRRITATION HEADACHE, DIZZINESS, COMA,CONFUSION

=====
===== First Aid Measures =====

First Aid:INCASE OF CONTACT, FLUSH SKIN AND EYES WITH PLENTY OF WATER
WHILE REMOVING CONTAMINATED CLOTHING. IF INHALED, REMOVE TO FRESH
AIR. CALL A PHYSICIAN IF SYMPTONS PERSIST. PERFORM ARTIFICIAL
RESPIRATION IF BREATHING HAS STOPPED.

=====
===== Fire Fighting Measures =====

Flash Point:104 F, 40 C TCC
Lower Limits:1.1
Extinguishing Media:CARBON DIOXIDE/DRY CHEMICAL-SMALL; POLYMER
FO
AM-LARGE FIRE
Fire Fighting Procedures:SELF-CONTAINED BREATHING APPARATUS AVAILABLE
FOR FIREMEN
Unusual Fire/Explosion Hazard:PRESSURE BUILD-UP FROM EXTREME HEAT MAY
CAUSE EXPLOSION. USE WATER TO COOL CANS. FOR FIRE:FOGNOZZLES

=====
===== Accidental Release Measures =====

Spill Release Procedures:REMOVE ALL SOURCES OF IGNITION (FLAMES, HOT
SURFACES, & ELECTRICAL, OR FRICTIONAL SPARKS). AVOID BREATHING
VAPORS. VENTILATE AREA. REMOVE WITH INERT ABSORBENT AND

PROVED FACILITY. DO NOT
INCINERATE CLOSED CONTAINERS.

Disclaimer (provided with this information by the compiling agencies):
This information is formulated for use by elements of the Department
of Defense. The United States of America in no manner whatsoever,
expressly or implied, warrants this information to be accurate and
disclaims all liability for its use. Any person utilizing this
document should seek competent professional advice to verify and
assume responsibility for the s
uitability of this information to their
particular situation.