

PRATT & LAMBERT-WICHITA DIV. -- 744-034 -- 8010-00-291-0889

=====
Product Identification
=====

Product ID:744-034

MSDS Date:01/01/1985

FSC:8010

NIIN:00-291-0889

MSDS Number: BDVKP

=== Responsible Party ===

Company Name:PRATT & LAMBERT-WICHITA DIV.

Emergency Phone Num:316-733-1361

CAGE:KO010

=== Contractor Identification ===

Company Name:PRATT & LAMBERT-WICHITA DIV.

Box:2153

CAGE:KO010

Company Name

:PRATT AND LAMBERT INC

Address:945 BURLINGTON

Box:206

City:KANSAS CITY

State:MO

ZIP:64141

Country:US

CAGE:92216

=====
Composition/Information on Ingredients
=====

Ingred Name:ALIPHATIC NAPHTHA

Fraction by Wt: 15.0%

ACGIH TLV:200 PPM

Ingred Name:ISOBUTYL ALCOHOL (SARA III)

CAS:78-83-1

RTECS #:NP9625000

Fraction by Wt: 8.0%

OSHA PEL:100 PPM

ACGIH TLV:50 PPM; 9293

EPA Rpt Qty:5000 LBS

DOT Rpt Qty:5000 LBS

Ingred Name:TOLUENE (SARA III)

CAS:108-88-3

RTECS #:XS5250000

Fraction

by Wt: 8.0%
OSHA PEL:200 PPM/150 STEL
ACGIH TLV:50 PPM; 9293
EPA Rpt Qty:1000 LBS
DOT Rpt Qty:1000 LBS

Ingred Name:VM&P NAPHTHA
RTECS #:SE7525000
Fraction by Wt: 15.0%
ACGIH TLV:200 PPM

Ingred Name:LEAD (SARA III)
CAS:7439-92-1
RTECS #:OF7525000
Fraction by Wt: 0.22%
OSHA PEL:0.05 MG/M3;1910.1025
ACGIH TLV:0.15 MG/M3;DUST 9192
EPA Rpt Qty:1 LB
DOT Rpt Qty:1 LB

=====
Hazards Identification
=====

Effects of Overexposure:INHAL:ANESTHETIC,IRRIT AIRWAY;SKIN/EYE

IRRIT.HEADACHE,DIZZINESS,COMA,CONFUSION

=====
First Aid Measures
=====

First Aid:FLUSH SKIN AND EYES WITH PLENTY OF WATER WHILE REMOVING
CONTAMINATED CLOTHING. IF INHALED:REMOVE TO FRESH AIR. CALL MD.IF
SYMPTOMS PERSIST. PERFORM ARTIF. RESP. IF BREATHING STOPPED.

=====
Fire Fighting Measures
=====

Flash Point:13F-11C TCC
Lower Limits:0.9
Extinguishing Media:CARBON DIOXIDE/DRY CHEMICAL-SMALL;POLYMER
FOAM-
LARGE FIRE
Fire Fighting Procedures:SELF-CONTAINED BREATHING APPARATUS AVAILABLE
FOR FIREMEN
Unusual Fire/Explosion Hazard:PRESSURE BUILD-UP FROM EXTREME HEAT MAY
CAUSE EXPLOSION. USE WATER TO COOL CANS. FOR FIRE:FOG NOZZLE

=====
Accidental Release Measures
=====

Spill Release Procedures:REMOVE ALL SOURCES OF IGNITION (FLAMES, HOT
SURFACES, & ELECTRICAL,STATIC, OR FRICTIONAL SPARKS).AVOID
BREATHING VAPORS. VENTILATE AREA.REMOVE WITH INERT ABSORBENT A

